

**ADDENDUM D - IFB 5236-BC**

**UNLV White Hall – Animal Care Facility**

**University of Nevada, Las Vegas**

**Purchasing Department**



**4505 Maryland Parkway**

**Las Vegas, Nevada 89154-1033**

**(702) 895-3521**

**Date of Addendum: August 26, 2016**

**Bid Opening: September 1, 2016 at 3:00 p.m.**

---

**THE FOLLOWING ADDITIONS, DELETIONS, CLARIFICATIONS AND/OR CHANGES SHALL BE MADE AND INCORPORATED IN THE SUBJECT IFB:**

***The addition of the following documents has been uploaded to the UNLV website [www.unlv.edu/purchasing/solicitations](http://www.unlv.edu/purchasing/solicitations).***

**Addendum D Attachment Specification Manual Revisions and Narrative**

**Question 1**

Concerning Addendum B; The answer to question #33 in this addendum states that the CMU exterior walls are "both split faced and honed. Interior of CMU is to be honed and furred out". If this is correct, furred out walls do not need to be honed but smooth finish. Where is the honed block to be placed?

Per drawings A6.00 and A2.00 CMU-1 is to be Standard (smooth) face grey and CMU-2 is to be split face grey. Also, room finish schedule indicates all room interior side of CMU walls are to be finished "W-1" (painted fiberglass faced gypsum board). Please clarify what finishes are to be used and what the CMU wall finishes are to be.

**Answer 1**

There is no honed block on this project, only standard and split-face per the material schedule.

**Question 2**

Per Addendum B there are several answer to the RFI's that state that the specifications have been updated or modified. I have not found any revised specification sections posted to the website or included in any of the addendum B sections. Please provide updated specification sections (Example – Questions & Answers #8)

**Answer 2**

See attached Specification Revisions 08-25-16

**ALL OTHER TERMS, CONDITIONS AND SPECIFICATIONS REMAIN THE SAME**