



**ADDENDUM 1 TO INVITATION FOR BID 5296-FG**

**UNLV UNLV STUDENT UNION HVAC INSULATION PROJECT**

**University of Nevada, Las Vegas  
Purchasing Department  
4505 Maryland Parkway  
Las Vegas, Nevada 89154-1033  
(702) 895-3521**

**Date of Release: February 21, 2018**

**Date and Hour of Opening: Tuesday February 27, 2018 at 2:00pm PST**

---

**THE FOLLOWING ADDITIONS, DELETIONS, CLARIFICATIONS AND/OR CHANGES SHALL BE MADE AND INCORPORATED IN THE SUBJECT RFP:**

**Question 1:** I see this project is very specific in its scope of work and that is to replace the insulation and cladding on the HVAV Duct Work. Please confirm that the correct prevailing wage classification to be used for this project is Mechanical Insulator.

**Answer 1:** A Mechanical Insulator will be required.

**Question 2:** Our alternate is we want to leave the current insulation and jacketing in place, except for the apparent damaged insulation and jacketing. I believe that 80-90% of what is in place is just fine. We plan on installing an Stucco Embossed aluminum jacket with corner angle to hold it all together.

**Answer 2:** No, the alternate is rejected as not equal.

Please Exhibits for UNLV Student Union Mechanical Layout and Duct Layout.

**ALL OTHER TERMS, CONDITIONS AND SPECIFICATIONS OF THIS INVITATION TO BID REMAIN THE SAME.**