



**ADDENDUM 5 TO INVITATION FOR BID 5319-FG**

**UNLV Police Station Improvements**

**University of Nevada, Las Vegas  
Purchasing Department  
4505 Maryland Parkway  
Las Vegas, Nevada 89154-1033  
(702) 895-3521**

**Date of Release: May 4, 2018  
Date and Hour of Opening: May 9, 2018 at 2:00pm PST**

---

**THE FOLLOWING ADDITIONS, DELETIONS, CLARIFICATIONS AND/OR CHANGES SHALL BE MADE AND INCORPORATED IN THE SUBJECT RFP:**

**Clarification:**

- 1. Fire alarm system - there is no fire alarm system in this building, and no requirement for adding one. Fire sprinkler work will need to get connected to the existing Fire Sprinkler monitoring system, AES Intellinet, and the original install was done by Robco Electric.**
- 2. Permits - all permits are paid for by UNLV with the exception of Sprinkler permit**
- 3. Conduit specifications - MC cable not permitted except for fixture whips - Attached spec section 16111 and revised sheet E-1.0**
- 4. Camera locations - Attached revised sheet E-5.0**
- 5. Locker Room lockers and Evidence Room high density shelving - to be provided and installed by Owner**

**ALL OTHER TERMS, CONDITIONS AND SPECIFICATIONS OF THIS INVITATION TO BID REMAIN THE SAME.**